

## Battery Room Survey

Dealer/Customer:Project:	Survey Performed By:			
Safety Product Requirements	Recommended BHS Products	Sample Illustrations	Regulations	
Drip Pans Approved method and materials for control of electrolyte spill ☐ Is spill control present? ☐ Are acid absorbent mats present in drip pans?	DK-SS UP-424		IFC 608.5 NFPA 1 Article 52 UFC Article 64 6404.4 OSHA 28 CFR 1926.441(a)(4)	
Spill Kits  Spill Kits are required for use by first responders. Kits should contain Personal Protective Equipment (PPE) for corrosive chemical protection, neutralizers and items to facilitate clean-up. Approved method to neutralize spilled electrolyte to a level of pH 7.0 to pH 9.0.  Is a Spill Kit present? Is Spill Kit complete (if not, indicate contents below)? Apron Gloves Face Shield Goggles Tyvex Coveralls Acid Resistant Boots Neutrasorb SOC's or Pillows Shovel PH Test Kit Other:	SK-6 SK-20 SK-55 SK-CAB		IFC 608.5	
Safety Protection Gear  PPE is required when entering battery rooms and working on battery systems.  ☐ Eye protection (goggles) ☐ Corrosive Resistant Gloves ☐ HV Insulated Gloves ☐ Corrosive Resistant Apron	PK-1200		OSHA 29 CFR 1910.133(a) OSHA 29 CFR 1926.28(a) NFPA 70E	
Eye Wash / Shower Station Suitable facilities for quick drenching or flushing of the eyes and body. Note condition.  Eyewash present? Type: (Portable, Plumbed, Qt. Bottles, Personal, Other) Shower present? Capacity (Portable): Does eyewash need maintenance?	PEW-700 EW-300 MEW-300 SEW-500 BES-1		OSHA 1910.151(c) OSHA 1926.441(a)(6)	

Safety Product Requirements	Recommended BHS Products	Sample Illustrations	Regulations
Battery & Safety Signage  Doors have approved signs and emergency equipment adequately identified.  Battery Spill Response Kit Personal Protective Kit Watch for Lift Trucks Battery Changing Area Do Not Use — Broken Needs Repair No Smoking Electrical Hazard Room Contains Energized Batteries and Corrosive Liquids Emergency Eye Wash	SP-1 PST	PERSONAL PROTECTIVE HIT	IFC 608.7 NFPA 1 Article 52.3.8 NFPA 70E
Hydrogen Gas Monitors  Ventilation is required to ensure that the hydrogen gas level does not exceed 1% by volume. Monitoring is used to confirm hydrogen gas levels remain within compliance levels.  Is a hydrogen gas monitor present?  Approximate date installed:  Number of sensors:  Size of room (approximate ft³):	HGD-1 HGD-1-DR	<b>4945</b>	IFC 608.6 IFC 609.6-7 UFC Article 64 6404.6 NFPA 70E
Ventilation  Ventilation shall be provided to ensure diffusion of the gases from the battery room and to prevent the accumulation of explosive gases. Hydrogen gas shall be maintained below 1% concentration. Note: Visit bhs1.com/batteryroom/ventilation for help determining ventilation needs.  □ Is the battery room closed in or open to outside air? □ Are there areas in the ceiling where hydrogen gas can accumulate?	BRVS HEF-KIT		OSHA 1926.441(a)(2) NEC 480.9(A) NEC 501.125(B) NEC 501.105(1)-3 IFC 608.6 NFPA 2
Carbon Monoxide & Smoke Detectors  An approved carbon monoxide detection system shall be installed an approved smoke detector shall be installed.  Carbon monoxide detectors present?  Date last checked:  Date last checked:  Date last checked:	CO-S-D	4. 4. 4. 4. 4. 4. 4. 4. 4. 4. 4. 4. 4. 4	IFC 608.9
Fire Extinguishers  Approved fire extinguishers shall be mounted and accessible.  □ Fire extinguishers present? □ Type: Class "C" or "CO2" Dry Chem: □ Date last checked:	FE-20		OSHA 1910.157(c)(1)
Battery Maintenance Proper battery maintenance items provide added safety.  Hydrometer Water De-ionizer (WDS-1) Water Cart (WC-HYDRO) Equipment Cleaning Kit (ECK-4) Water Gun (WG-X)	WDS-1 WC-HYDRO ECK-4 WG-X		

Safety Product Requirements	Recommended BHS Products	Sample Illustrations	Regulations
Training Program  Training shall be provided regarding the hazards of the equipment in their work area for ALL persons entering the battery room.  Training program in place? Are training records documented? Is a training standard documented for personnel? Are all persons who access battery room trained on hazards? Have product manuals and operator training DVD been provided? Comments:			NFPA 70E 110.2
Battery Room Floors Floors shall be of acid resistant construction unless protected from acid accumulations.  ☐ Does battery room floor currently have an epoxy applied to the concrete floor? ☐ Is there damage to existing epoxy or concrete? ☐ If yes, take photos. ☐ (Operator Aboard Battery Extractor application) Has defined travel path been profiled to verify the FMIN rating?			OSHA 1926.441(a)(4)
Cable Management Charging apparatus shall be protected from damage by trucks.  ☐ Is there any damage to the charger cables or connectors? ☐ Are the charger cables and connectors supported from resting on the battery stand or floor?	CWB CWB-V1 CR-MT CR-1 CR-M CCR-12HD		OSHA 1926.441(b)(2)
Lifting Beam Staging Stand Battery lifting devices shall be stored when not in use.  ☐ Is there any damage to existing lifting beam? ☐ Is there a secure storage device for lifting beam while not in use?	CS-BLB		ASME B30.20-2003
The items referenced above are intended to assist in meeting the regulations refer jurisdiction to jurisdiction. This survey should not be considered an exhaustive lis maintain full compliance with all applicable regulations. Please consult legal cour <b>Comments:</b>	st of applicable regulations	s in your area. It is the respon	nsibility of the end user to verify and







